

355696108

PHONE: 330-782-8883

TO:

WORK PERFORMED AT:

Town, Cleveland	
2600 S. Edison	
Youngstown, OH	
441-600-4443	

DATE

YOUR WORK ORDER NO.

OUR BID NO.

Oct 29 2013

CHECK NO.

DESCRIPTION OF WORK

Goodman Furnace

- Found: Flood Damaged Furnace

- Bad main Blower motor - replaced

- Bad main Control board - replaced

- Bad Auxiliary Gas Valve - replaced

Parts & Labor

\$778.00

System now operational

All Material is guaranteed to be specified, and the above work was performed in accordance with the drawings and specification provided for the above work and was completed in a substantial workmanlike manner for the agreed

sum of \_\_\_\_\_ Dollars ( )

This is a ( ) partial ( ) FULL INVOICE DUE AND PAYABLE BY \_\_\_\_\_ MONTH \_\_\_\_\_ DAY \_\_\_\_\_ YEAR

*[Signature]*

SIGNATURE OF CUSTOMER

Send payment to:  
101 LAMAR AVE.  
YOUNGSTOWN, OH 4450